
## **RAIL 4 WET S4WD**

**RECESSED FLANGELESS. DIRECT** 





PART #:	
PREP BY:	DATE:
PROJECT:	QTY:
NOTES:	
APPROVAL SIGNATURE:	DATE (DD/MM/YYYY):

PERFORMANCE SUMMARY @ 3500K		Meta Blanc MB	Luma Span LS	Luma Asym. LA	Polycarbonate PC		
Light Level		50	50 50 50		50		
Lumens per	80 CRI	574	522	525	585		
foot	90 CRI	502	457	459	512		
Wattage per foot		5.7	4.7	4.4	5.8		
Efficacy	80 CRI	100	112	118	102		
Efficacy	90 CRI	88	97	104	88		
L70 Estimate (h)	)	≥ 60,000 hrs					

See complete Light Level Performance and Photometric Data on p2

- Efficacy up to 122 LPW
- Wet location and IP54 rated
- · Continuous direct optics with no breaks
- · Constructed of non-corrosive components
- Standard natatorium powder coat finish














OTHER RAIL WET SERIES PRODUCTS



### ORDERING LOGIC

#### Example Part Number: S4WD-35K-8-MB-NW-1001-DF-3-OO

3. LENGTH 2 2 ft 3 3 ft 4 4 ft 5 5 ft 6 6 ft	4	4. PATTERN  GA  GA×B  UA×B×C	1 Square	7	8	DF 9 5. OPTICS	10	6.	12 FINISH		
3. LENGTH 2 2 ft 3 3 ft 4 4 ft 5 5 ft	4	4. PATTERN  GA  GA×B  UA×B×C	1 Square	7		5. OPTICS	10				
<ol> <li>2 2 ft</li> <li>3 3 ft</li> <li>4 4 ft</li> <li>5 5 ft</li> </ol>		G <u>A</u> G <u>A</u> × <u>B</u> U <u>A</u> × <u>B</u> ×C	Square					6.	FINISH		
		Standard Patter  A G Square  A: 8:	4. PATTERN 1  GA Square  GAXB Rectangle  UAXBxC U-Shape  L-Shape C Custom Pattern* _ None (leave space empty)  Standard Patterns Minimum Lengths  A=4ftmin. B=4ftmin. B=4ftmin. B=4ftmin. B=3ftmin. B=3ftmin. B=3ftmin. B=3ftmin. B=3ftmin. B=3ftmin.		A = 3 ft min. B = 3 ft min.	MB Meta Blanc IK10 PC Polycarbonate IK10 LS Luma Span (Batwing) LA Luma Asymmetric  MB: Acrylic opal diffuse lens LS, LA: Acrylic high output semi-diffuse lens PC: Semi-diffuse lens  PC: Semi-diffuse lens			6. FINISH  NSA Satin Aluminum  NW White  NB Black  NC Custom  Specify RAL:		
, ,	om Length*	Lengths and a pattern are re	drawing of custom equired on page 3	Outside 90	00°						
	8. CIRCUITRY			-	10. VOLTAGE	11. CON	TROLS	1:	2. OPTIONS		
C Custom Range. Specify lumens: (Total lumens between (Limited to ambient		ttery Pack* ted) nt		, ,	1 120 V 2 277 V 3 347 V 4 UNV (120 - 277 V)	DD 0 DD 0	ensor utdoor Dusk to awn Sensor one	o	90 CRI, High R9  None (leave space empty)		
In 0	9 9 ft 10 10 ft 11 11 ft 12 12 ft RA Conti (Repla C Custo	9 9 ft 10 10 ft 11 11 ft 12 12 ft RA Continuous Rows (Replace "A" with length in feet) C Custom Length*  8. CIRCUITRY 1 1 Circuit EM Emergency Air (remote moun (Limited to ambier temperatures dow	9 9 ft 10 10 ft 11 11 ft 12 12 ft RA Continuous Rows (Replace "A" with length in feet) C Custom Length*  8. CIRCUITRY 1 1 Circuit EM Emergency/Night Light B Emergency Battery Pack* (remote mounted) (Limited to ambient temperatures down to 0°C)	9 9 ft 10 10 ft 11 11 ft 12 12 ft RA Continuous Rows (Replace "A" with length in feet) C Custom Length*  8. CIRCUITRY n/f Im/f B Emergency / Night Light B Emergency Battery Pack* (remote mounted) (Limited to ambient	9 9 ft 10 10 ft 11 11 ft 12 12 ft RA Continuous Rows (Replace "A" with length in feet) C Custom Length*  8. CIRCUITRY In/f Im/f B Emergency / Night Light B Emergency Battery Pack* (remote mounted) (Limited to ambient)  A G A G A G A U U C U-Shape  A = 4ft min. B = 4ft min. B = 4ft min. C = 3ft min. Select corn. Custom Patterns* Lengths and a drawing of custom pattern are required on page 3 Unside 90  DF Recessed Drywall Flangeless	9 9 ft 10 10 ft 11 11 ft 12 12 ft RA Continuous Rows (Replace "A" with length in feet) C Custom Length*  8. CIRCUITRY In/f Im/f B Emergency / Night Light B Emergency Battery Pack* (remote mounted) (Limited to ambient)  A=3 ftmin. B+4ftmin. B+4ftm	## Square Rectangle   U.Shape   L.Shape   PC: Semi-diffus	9 9 ft 10 10 ft 11 11 ft 12 12 ft RA Continuous Rows (Replace "A" with length in feet) C Custom Length*  8. CIRCUITRY In/f Im/f B Emergency / Night Light B Emergency Battery Pack* (remote mounted) (Limited to ambient ween  Ween  Rectangle  A = 4 ftmin. B + 4 ftmin. B + 4 ftmin. B + 4 ftmin. B + 4 ftmin. C + 3 ftmin. B + 4 ftmin. C + 3 ftmin. B + 4 ftmin. C + 3 ftmin. B + 4 ftmin. B + 4 ftmin. C + 3 ftmin.	9 9 ft 10 10 ft 11 11 ft 12 12 ft RA Continuous Rows (Replace "A" with length in feet) C Custom Length*  8. CIRCUITRY In/f Im/f B Emergency / Night Light B Emergency Battery Pack* (remote mounted) (Limited to ambient)  A = 4 ftmin. B = 3 ftmin. B = 3 ftmin. C = 3 ftmin. C = 3 ftmin. B = 3 ftmin. C = 3 f		

 $\hbox{$^*$Consult factory.} \mid {^1} \hbox{Pattern record drawings showing mounting locations will be sent out upon order.}$ 

Select Driver: ☐ Factory option 0-10V, 1% Dimming

☐ **LHE** Lutron H-Series Hi-lume 1% EcoSystem LED Driver

☐ **L5E** Lutron 5-Series EcoSystem LED Driver

Consult factory for -40 drivers.



#### LIGHT LEVEL PERFORMANCE & PHOTOMETRIC DATA

3500K, 80 CRI, 0-10V Dimming (Standard)


		Met	a Blanc (	MB)	Polycarbonate (PC)		Luma Span (LS)			Luma Asymmetric (LA)			
	Light Level	Lumens per foot	Wattage per foot	Efficacy (LPW)	Lumens per foot	Wattage per foot	Efficacy (LPW)	Lumens per foot	Wattage per foot	Efficacy (LPW)	Lumens per foot	Wattage per foot	Efficacy (LPW)
<b>35</b> 381 3.9		99	388	3.9	101	363	3.2	115	364	3.0	122		
<b>50</b> 574 5.7 100		585	5.8	102	522	4.7	112	525	4.4	118			
	<b>75</b> 790 8.1 97		807	8.1	99	772	6.9	111	772	6.4	121		
	<b>100</b> 1090 11.8 93		1115	11.7	95	1025	9.4	109	1016	8.8	116		
	IES File	S4WD-35K-4-MB-75		S4WD-35K-4-PC-75			S4WD-35K-4-LS-75			S4WD-35K-4-LA-75			
	Distribution % (Down / Up)	100 / 0			100 / 0			100 / 0			100 / 0		
175	Zonal Lumens (0-90 / 90-180)	3156 / 0		3227 / 0			3086/0			3088 / 0			
Light Level <b>7</b>	Distribution Curve		190			1500			1500 1200 600			2000	

## Lumen Adjustment Factor (Standard)


Color Temp	80 CRI	90 CRI
3000K	0.984	0.880
3500K	1.000	0.875
4000K	1.032	0.879

Metalumen's light level performance metrics are subject to manufacturers component tolerances.

#### **CROSS SECTION**



#### WIRING



#### **SPECIFICATIONS**

Due to the Continuous Improvement Policy at Metalumen, we reserve the right to change our specifications without notice.

Housing: Rigid extruded aluminum body, 2.0mm (0.08") nominal wall thickness. Aluminum formed end caps. Optical System: Metalumen luminaires are designed to utilize leading edge LED technology combined with luminaire optimized reflectors and our custom diffusers, resulting in industry leading optical performance.

CRI: 83+ for 3500K, 80 minimum for all hours (ASTM B117). For custom colors,

CCTs in standard configurations. **Lumen Maintenance:** Minimum 50,000h with TM-21 lumen maintenance of 85% @ 25°C ambient temperature (calculated based on IESNA LM-80-08 LED test data). L70: ≥ 60 000hrs.

**Finish:** Standard natatorium powder coated finish in satin aluminum, white and black. Exceeds 4000 salt spray hours (ASTM R117). For custom colors

contact factory. **Weight:** 3 lb/ft

**Mounting:** Mounting brackets provided.

**Drivers:** Metalumen offers dimming\* drivers as a standard on our entire LED product offering at 0-10V. Dimming range is 1%-100%. Power factor is > 90%. Class 2 rating. Drivers are integral. Consult factory for -40 drivers.

**Approvals:** All components are UL/ CSA/QPS recognized or listed. RoHS compliant. This product is cULus listed. **Environment:** Suitable for wet locations -22°F / -30°C start ambient temperature. Suitable for natatorium environments.

\*Standard drivers compatible with passive/ sinking dimmers. Please contact Metalumen if active/sourcing dimmer support is required.

#### WARRANTY

Metalumen will warrant defective luminaires for 5 years from date of purchase. Warranty is valid if luminaire is installed and used according to specification. If defective, Metalumen will send replacement boards or drivers at no cost along with detailed replacement instructions and instructions on how to return defective components to Metalumen.



#### **PATTERNS**

Select Pattern:	T-SHAPE (C)	CROSS / X-SHAPE (C)			
Pattern Configuration	⊢—B—— I <b>— T —</b> A I	⊢ B — I A <b>— I</b> I			
Indicate Desired Lengths (ft)	Consult Factory				
Minimum Lengths	A = 3 ft B = 6 ft	A = 6 ft B = 6 ft			

# A custom pattern configuration drawing is required in the grid below

Approval drawings will be sent out upon order showing mounting locations.

